



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1A 080442 0025 Rev. 00

Initial No. CLS1A 13 06 80442 001

Reports:

BSI 285/4349809 (Model EEW-6s), BSI 285/4349809 (Model EEW-9s), BSI 285/7000272-1, BSI 285/7146036-1 Issue 2, BSI 285/7146036-3, BSI 285/7146036-4, BSI 285/7290888, BSI 2244/8150392 (Model EEW-6S), BSI 2244/8150392 (Model EEW-9S), TÜV SÜD PSB 7191059976-MEC13/04-DA, TÜV SÜD PSB7191061519-MEC13/04-DA

Product Details:

Brand	Model	Specification	Fire Rating Achieved
EVERSAFE, FIRESAFE, FIREHUNTER, RED PANTHER, HART	EEW-6	6 litres water type, stored pressure type portable fire extinguisher	13A
	EEW-9	9 litres water type, stored pressure type portable fire extinguisher	21A

Page 2 of 2

Issued on: 2018-11-02

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is part of a full Report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv.sud-psb.sg