

CERTIFICATE OF CONFORMITY

This certificate hereby certified that the product as detailed in this certificate has satisfactorily complied with the requirements of the appropriate Standard(s) and the Certification Scheme Requirement of WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.

Name and Address of Certificate Holder

EVERSAFE EXTINGUISHER SDN. BHD.

LOT 878, JALAN SUBANG 9,
TAMAN PERINDUSTRIAN SUBANG,
47500 SUBANG JAYA, SELANGOR,
MALAYSIA

Scope of Certification


Name of Scheme	
PRODUCT CERTIFICATION SCHEME	

Product Name	Product Standard(s)
LANDING VALVES FOR WET RISERS	MS 1210: PART 1: 1991
Product Descriptions	
(refer to SCHEDULE)	
Brand Name	
EVERSAFE, FIRESAFE, RED PANTHER	

Name and Address of Manufacturer	
EVERSAFE EXTINGUISHER SDN. BHD. LOT 878, JALAN SUBANG 9, TAMAN PERINDUSTRIAN SUBANG, 47500 SUBANG JAYA, SELANGOR, MALAYSIA	

Certification Number	Initial Certification	3 MARCH 2021
WCM PC 000147	Certificate Validity	2 MARCH 2022

This certificate is awarded on the basis of an assessment against the standard(s) for conformity which includes the manufacturer's production control system, production facilities, product conformity to standard coupled with assessment of the supporting quality management system. This Certificate remains the property of WCM and shall be returned upon request. The use of this certificate is subjected to the terms and conditions of the Certification Agreement. This certificate is remains valid subject to satisfactory yearly surveillance assessment.



Certificate is issued by

Kamaruddin Bin Abu Samah

Managing Director

WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.

(1307169-V)

LOT NO. 1 TINGKAT 6, WISMAPKPS
PERSIARAN PERBANDARAN,
SEKSYEN 14, 40675 SHAH ALAM
SELANGOR, MALAYSIA
NO. TEL: 03-5524 1656
www.watermarks.com.my



WCM000147



PRODUCT CERTIFICATION SCHEME

The certificate holder is solely responsible for the quality and conformity of the product as detail in this certificate with the requirements of the appropriate Standard(s) and the Certification Scheme Requirements of WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.

FLANGED				
BRAND	MODEL	TYPE	RATING	SIZE
EVERSAFE FireSafe Red Panther	VLRF	LANDING VALVE, RIGHT ANGLE FLANGED	PN 16 (LOW PRESSURE)	NOMINAL SIZE : DN 65
	VLOF	LANDING VALVE, OBLIQUE FLANGED		
	RLOF	SELF-REGULATING VALVE, OBLIQUE FLANGED		

SCREWED END				
BRAND	MODEL	TYPE	RATING	SIZE
EVERSAFE FireSafe Red Panther	VLRS	LANDING VALVE, RIGHT ANGLE SCREWED END	PN 16 (LOW PRESSURE)	NOMINAL SIZE : DN 65
	VLOS	LANDING VALVE, OBLIQUE SCREWED END		
	RLOS	SELF-REGULATING VALVE, OBLIQUE SCREWED END		

Material : Copper Alloy
 Material Grade : LG 2
 Coating : Epoxy Coat (Fusion Bonded)

End of page

Initial Certification : 3 MARCH 2021

Issue Date : 3 MARCH 2021

Certificate Validity : 2 MARCH 2022

Certification Number : WCM PC 000147

This page is not valid if it is not printed or displayed together with certificate on the front page.

