

## Kitemark™ Certificate

This is to certify that:

Eversafe Extinguisher Sdn Bhd  
Lot 878 Jalan Subang 9  
Taman Perindustrian Subang  
47500 Subang Jaya  
Selangor  
Malaysia

Holds Certificate Number:


KM 61549

In respect of:

**BS EN 3**  
**Portable fire extinguishers**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 02/07/2003

Latest Issue: 26/01/2017



003

Page: 1 of 3

...making excellence a habit.™

# Kitemark™ Certificate

No. KM 61549

Model No.	Description
EED-1, CR-EED-1	1 kg ABC powder, stored pressure. Fire rating 5A & 34B.
EED-2, CR-EED-2	2 kg ABC powder, stored pressure. Fire rating 13A & 55B.
EED-2h, CR-EED-2h	2 kg ABC powder, stored pressure. Fire rating 13A & 70B.
EED-3, CR-EED-3	3 kg ABC powder, stored pressure. Fire rating 13A & 89B.
EED-4N, CR-EED-4N	4 kg ABC powder, stored pressure. Fire rating 21A & 113B.
EED-6, CR-EED-6	6 kg ABC powder, stored pressure. Fire rating 43A & 233B.
EED-9, CR-EED-9	9 kg ABC powder, stored pressure. Fire rating 43A & 233B.
EED-12, CR-EED-12	12 kg ABC powder, stored pressure. Fire rating 43A & 233B.
EED-4c, CR-EED-4c	4 kg ABC powder, cartridge operated. Fire rating 21A & 89B.
EED-6c, CR-EED-6c	6 kg ABC powder, cartridge operated. Fire rating 27A & 183B.
EED-9c, CR-EED-9c	9 kg ABC powder, cartridge operated. Fire rating 34A & 233B.
EED-12c, CR-EED-12c	12 kg ABC powder, cartridge operated. Fire rating 43A & 233B.
EED-12cMX, CR-EED-12cMX	9 kg BC powder, cartridge operated. Fire rating 233B.
EEF-2s, CR-EEF-2s	2 litre foam, stored pressure. Fire rating 5A & 34B.
EEF-2s+, CR-EEF-2s+	2 litre foam + freeze point depressant, stored pressure. Fire rating 5A & 34B.
EEF-6s, CR-EEF-6s	6 litre foam, stored pressure. Fire rating 13A & 144B.
EEF-6s+, CR-EEF-6s+	6 litre foam + freeze point depressant, stored pressure. Fire rating 13A & 144B.
EEF-6cs, CR-EEF-6cs	6 litre foam, cartridge operated. Fire rating 13A & 144B.
EEF-9s, CR-EEF-9s	9 litre foam, stored pressure. Fire rating 21A & 183B.
EEF-9s+, CR-EEF-9s+	9 litre foam + freeze point depressant, stored pressure. Fire rating 21A & 183B.
EEF-9c, CR-EEF-9c	9 litre foam, cartridge operated. Fire rating 13A & 183B.
EEF-9cs, CR-EEF-9cs	9 litre foam, cartridge operated. Fire rating 21A & 183B.
EEW-6s, CR-EEW-6s	6 litre water, stored pressure. Fire rating 13A.
EEW-6cs, CR-EEW-6cs	6 litre water, cartridge operated. Fire rating 13A.
EEW-9s, CR-EEW-9s	9 litre water, stored pressure. Fire rating 21A.
EEW-9cs, CR-EEW-9cs	9 litre water, cartridge operated. Fire rating 21A.

First Issued: 02/07/2003

Latest Issue: 26/01/2017

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 61549

Model No.	Description
EEK-2s, CR-EEK-2s	2 litre wet chemical, stored pressure. Fire rating 5A & 5F.
EEK-6s, CR-EEK-6s	6 litre wet chemical, stored pressure. Fire rating 8A & 75F.
EEK-9s, CR-EEK-9s	9 litre wet chemical, stored pressure. Fire rating 13A & 75F.
EEK-6cs, CR-EEK-6cs	6 litre wet chemical, cartridge operated. Fire rating 8A & 75F.
EEK-9cs, CR-EEK-9cs	9 litre wet chemical, cartridge operated. Fire rating 13A & 75F.
EEC-2Ae2, CR-EEC-2Ae2	2 kg carbon dioxide, Aluminium body. Fire rating 34B.
EEC-2e2, CR-EEC-2e2	2 kg carbon dioxide, steel body. Fire rating 34B.
EEC-5Ae1, CR-EEC-5Ae1	5 kg carbon dioxide, aluminium body. Fire rating 55B.
EEC-5e1, CR-EEC-5e1	5 kg carbon dioxide, steel body. Fire rating 55B.

All the above products are certified to BS EN 3-7:2004+A1:2007.

Note. CR prefix indicates additional corrosion resistant model variant.

The above portable fire extinguisher models falling within the scope of this certificate may be marketed under the following brand names:

FireSafe  
Red Panther

First Issued: 02/07/2003

Latest Issue: 26/01/2017

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.